



**Town of Bowling Green – Public Works
and Utilities Council Monthly
Report/Project Update
For March 2018**

Prepared By: Billy Deavers

Date: March 29, 2018

Additional and/or Support Materials Attached: Yes

No

Ongoing:

Wastewater Operations:

- White Oak Electric working on Control Panel and communication errors on UV Lights
Some parts still on order.
- Continuing to work on sludge drying beds to keep solids inventory
Low

Water Operations:

- Working on Lead and Copper Materials Survey for VDH
- Chlorine Pumps being Repaired at Well #1

Public Works:

- Shawn and Frank have attended classes, and will soon test to obtain Pesticide
Applicator License

Completed:

Wastewater Operations:

- Pumps at Heritage Pines Lift Station have been pulled and de-ragged, Wetwell
Was pumped prior, to remove large amounts of rags and build up
- New Alternator switch was installed on Bowling Green Meadows Lift Station
- Had Sand Filter #3 Reject line jetted and filter back online
- Billy and Alicia attended DEQ's Permit Reporting Class

Water Operations:

- All Hydrants have been flushed
- Meters were read March 5th and 6th

Heads up:

- Propane Service has been switched from Amerigas to E.M.Gray and Son.
Tanks switched out at Town Hall and The WWTP

Public Works 2nd Quarter Priorities

- **Fire Hydrant Replacements – Harding Drive (2) \$3,000 Getting bids on the remaining (6).**
- **Meter Replacements – (5) Commercial Meter first.**
- **Lee Street Meter Box – Getting Estimate.**
- **Well House Door Replacements – (6) Getting Estimates.**
- **Main Street Sidewalks – Two tree were removed in the fall; matching concrete need to be poured to finish the job.\$500**
- **Lift Stations – Electrical work at Lacey Lane and Oak Ridge. \$15,000***